

ഭരണഭാഷ- മാതൃഭാഷ



**Kollam Municipal Corporation**

പിൻ കോഡ്- 691001

**GSTIN:32AAALK1455B1ZR**

ഫോൺ നമ്പർ : 0474-2746193

**<https://kollamcorporation.gov.in>, [secretarykollam@gmail.com](mailto:secretarykollam@gmail.com)**

നമ്പർ: 1112492-2025

തീയതി : 22-05-2025

**HEALTH AND SANITATION CERTIFICATE**

This is to Certify the Sree Narayana Public School, Vadakkevila has maintained a very good standard of hygiene and Sanitation.

This certificate is issued at the request of the Principal Sree Narayana Public School for submission to the CBSE .

  
Clean City Manger





**SREE BUDDHA COLLEGE OF ENGINEERING, PATTOOR (AUTONOMOUS)**  
**DEPARTMENT OF BIOTECHNOLOGY AND BIOCHEMICAL ENGINEERING**  
**ACCREDITED BY NAAC & NBA**

Pattoor P.O, Alapuzha, Kerala 690529, Contact No: 9400691353, 9446014317

Pollution Control Board Approved Laboratory

Approval No: PCB/LAB/C50/2022



**Ref No: SBC/BTBCE/WQ/25/23**

**Issued to:** S.N Public School, Vadakkevila, Kollam

**Source of sample:** Well Water (sample-1)

**Sample received dates:** 25/04/2025

Tested parameters	Observed values	Reference range
<b>Bacteriological Analysis Result</b>		
Presence of Coliform bacteria	Absent	Nil
Total Coliform count	00/100ml	< 2/100 ml
Presence of <i>E-coli</i>	Absent	Nil
Presence of Faecal Coliforms (presumptive test)	Absent	Nil
<b>Chemical Parameters Analysis Result</b>		
Colour & Appearance	Agreeable	Not more than 2 Hazen units/true colour units
Odour	Agreeable	Agreeable
Taste	Agreeable	Agreeable
Turbidity	Nil	Not more than 5 NTU
pH	7.2	6.5 to 8.5
Chlorides	15.01ppm	Not more than 250 ppm
Hardness -Total	18ppm	Not more than 200 ppm
Total solids	0.1ppm	Not more than 200 ppm

**Remarks:** Water is suitable for drinking purpose.

Date: 29/04/2025

Pattoor

Dept. of Biotechnology & Biochemical Engg.  
Sree Buddha College of Engg.  
Pattoor P. O., Alappuzha Dist.,  
PIN - 690 529

  
**Chief analyst**

Department of Biotechnology and Biochemical Engineering.  
Sree Buddha college of Engineering, Pattoor (Autonomous)