




**SREEBUDDHA COLLEGE OF ENGINEERING, PATTOOR**  
**DEPARTMENT OF BIOTECHNOLOGY AND BIOCHEMICAL ENGINEERING**  
**ACCREDITED BY NAAC & NBA**  
Pattoor, P.O, Alapuzha, Kerala 690529, Contact No: 9048928104, 9446014317  
Pollution Control Board Approved Laboratory  
Approval No: PCB/LAB/C50/2022



Ref No: SBC/BTBCE/WQ/23/57

<b>Issued to: S.N. PUBLIC SCHOOL, KOLLAM</b>		
<b>Source of sample: Well Water</b>		
<b>Sample received dates: 17/04/2023</b>		
Tested parameters	Observed values	Reference range
<b>Bacteriological Analysis Result</b>		
Presence of Coliform bacteria	NIL	Nil
Total Coliform count	0/100 ml	< 2/100 ml
Presence of <i>E-coli</i>	Nil	Nil
Presence of Faecal Coliforms	Nil	Nil
<b>Chemical parameters analysis result</b>		
Colour & Appearance	Agreeable	Not more than 2 Hazen units/true colour units
Odour	Agreeable	Agreeable
Taste	Agreeable	Agreeable
Turbidity	Nil	Not more than 5 NTU
pH	7.4	6.5 to 8.5
Electrical conductivity	0.1 Siemens/cm <sup>2</sup>	-
Chlorides	45.04 ppm	Not more than 250 ppm
Hardness -Total	84 ppm	Not more than 200 ppm
Total solids	0.1 ppm	Not more than 200 ppm

Date:  
20/04/2023

**Chief analyst**   
20/4/23  
Department of Biotechnology and Biochemical Engineering  
Sree Buddha college of Engineering, Pattoor

Pattoor

Dept. of Biotechnology & Biochemical Engg.  
Sree Buddha College of Engg.  
Pattoor P. O., Alappuzha Dist.,  
PIN - 690 529



KOLLAM MUNICIPAL CORPORATION

FILE NO: VZ/H/1918/23

DATE: 05/08/23.

**SANITATION CERTIFICATE**

It is certified that ..... Sree Narayana Public School .....  
.....had kept very good standard of hygiene and  
sanitation. Also certified that they have provided safe drinking water.

This certificate is given as per the request of ..... Principal .....  
..... Sree Narayana Public School .....  
to produce before ..... Central Board of Secondary Education, New Delhi .....



[Signature]  
09/08/23  
Health Officer  
PRAMODE A.S  
Health Supervisor  
Kollam Municipality Corporation  
Tel. 9495 67 0282